

ROCKFORD BOARD OF EDUCATION INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES FOR SCHOOL DISTRICT NO. 205 ROCKFORD, ILLINOIS

IFB No. 18-20 Demolition of Walker Elementary School

DATE: January 25, 2018

RE: ADDENDUM NO. 4

To All Bidders:

Attached are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 2nd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Purchasing Department by email at <u>purchasingdeptstaff@rps205.com</u>.

Please note that both the original date <u>and</u> time of the bid opening has changed. Bids are due at 3:00 PM on Tuesday, January 30, 2018 and will be opened at that time.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood Director of Purchasing

RICHARD L. JOHNSON ASSOCIATES | ARCHITECTS

ADDENDUM FOUR

RPS205 Project No.: **18-20**

RLJA Project No.: 17-064

Date: January 25, 2018

Subject: CHANGES to the BIDDING DOCUMENTS

Project: WALKER SCHOOL BUILDING DEMOLITION 1520 POST AVENUE ROCKFORD, ILLINOIS 61103

Bids Due: 3:00PM (CST), TUESDAY, JANUARY 30, 2018

From: RICHARD L. JOHNSON ASSOCIATES, INC. 4703 CHARLES STREET ROCKFORD, IL 61108

To: ALL PROJECT DOCUMENT HOLDERS

Please reproduce this Addendum as needed and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely, RICHARD L. JOHNSON ASSOCIATES, INC.

Ana

Richard L. Johnson, Principal

This Addendum consists of:

a. Pages 1-2

CLARIFICATIONS

1.1. After today's walk through, it was believed that there is a single 4" water service serving the school from Post Ave. The contractor shall be responsible locating and capping the water service at the main. The contractor shall also be responsible for patching the street.

CHANGES to the DRAWINGS

2. <u>SHEET A101</u>

2.1. GENERAL UTILITY NOTES – DEMOLITION

WATER; Delete as written and replace with the following:

"CITY OF ROCKFORD TO PULL METER, CONTRACTOR SHALL CAP LINE AT THE MAIN – PATCH STREET AS REQUIRED."

END ADDENDUM NUMBER 4