ADDENDUM TWO

Project No.:

14-044

Date:

October 30, 2015

Subject:

CHANGES to the BIDDING DOCUMENTS

Project:

WINDOW REPLACEMENT FOR

KENNEDY MIDDLE SCHOOL ROCKFORD PUBLIC SCHOOLS

ROCKFORD, ILLINOIS

Bids Due:

2:00PM, WEDNESDAY, NOVEMBER 4, 2015

From:

RICHARD L. JOHNSON ASSOCIATES, INC.

4703 CHARLES STREET ROCKFORD, IL 61108

To:

ALL PROJECT DOCUMENT HOLDERS

Please reproduce this Addendum as needed, and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely

RICHARII L. JOHNSON

JOHNSON ASSOCIATES, INC.

Scott R. Johnson, AIA, LEED AP

This Addendum consists of:

Pages 1 thru 2

8 1/2 x 11 Addendum Drawing ADA2.1



NOTE: Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

CHANGES to the PROJECT MANUAL

1. **GENERAL ITEMS**

- **1.1.** No school activities will take place in the building over the summer.
- **1.2.** Contractor to modify existing head conditions as shown on the details. If determined that some head conditions contain asbestos, then a credit will be determined at a later date to remove this demolition from the Contractor's scope of work.
- 1.3. Rockford Public Schools will not give out the projected budget for the project.


CHANGES to the DRAWINGS

2. DRAWING A111

2.1. See attached addendum drawing ADA2.1 showing frame type W12. All glazing in the doors, sidelights and transom shall be changed to a GL-1* glass type. GL-1* glass type shall be the same as GL-1 except tempered shall be replaced with laminated.

END ADDENDUM NUMBER 2

ADDENDUM NUMBER 2 October 30, 2015 Project Number: 14-044
PAGE 2



NOTE:

ORIGINAL DRAWINGS SHALL REMAIN IN FORCE EXCEPT FOR CHANGES HERE-IN NOTED

WINDOW REPLACEMENT AT KENNEDY MIDDLE SCHOOL ROCKFORD PUBLIC SCHOOL DISTRICT 205 501 SEVENTH STREET ROCKFORD, ILLINOIS 61104



JOB NO: 14-044

ADDENDUM DWG.

DATE: October 30, 2015

ADA2.1